

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 011

Dated: 07/07/2026

It is certified that an inspection team headed by Mr. Anshul Kumar (Sampling Assistant)
(Name of Officers with designation) from District Level Water Analysis Lab. PHED UPJN (R), Aligarh
inspected the ST. Fidelis School, Kheda Khush Khabar, Jirahider, Aligarh
(Name & Address of the school) on 04/07/2026 (date of inspection) and on the basis of
Water Test Report (Attached) bearing no. ALI/At:1sch./016/2026-27 dated 07/07/2026
of District Level Water Analysis Laboratory (PHED Lab) certified that
the ST. Fidelis School, Kheda Khush Khabar (Name of school) has safe drinking water
facilities for the students and members of staff of the institution. School is also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the
Central/ State/ U.T. Govt.

This certificate is valid till 01 Year

Signature with Seal:

Name

Designation

Name & Address of the Office / Department :

(अनिल कुमार)

अभिषेक अभियन्ता

Mr. Anshul Kumar (Sampling Assistant)

अभिषेक अभियन्ता (ग्रामीण)

Assistant Engineer (S&M)

UPJN (Rural), Aligarh

To

ST. Fidelis School
Kheda Khush Khabar, Jirahider, Aligarh
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

PRINCIPAL

ST. FIDELIS SCHOOL
KHEDA KHUSH Khab
ALIGARH

MANAGER

ST. FIDELIS SCHOOL
KHEDA KHUSH Khab
ALIGARH



TC-18011

District Level Water Analysis Laboratory Aligarh
Address: First Floor, Office of Superintending Engineer U.P. Jal Nigam (Urban)
Aligarh 202001

Water Test Report

Report No: ALI/Sch./016/2026-27 Issue Date: 07/07/2026 Page No: 01

Customer Details

Office Name and Address: **ST. FIDELIS SCHOOL**
Ref Letter No & Date: **APP/Testing/04-07-2026**

Basic details of sample

District	Aligarh	Block	-
Gram Panchayat	-	Village / NPP	-
Habitation	School	Location	St. Fidelis School, Kheda Khush Khabar, Jiroli Dor Post, Aligarh (U.P.) 202140
Water Source	Submersible	Sample No.	01
Quantity of Sample	1000 ml	Date of Collection	04/07/2026
Receiving Date	04/07/2026	Sample Collector	Mr. Manish
Sample Depositor	Mr. Manish	Sampling Method	As per IS 17614: Part 1:2021 & APHA 24 th Edition
Analysis Start Date	06/07/2026	Analysis Completion Date:	07/07/2026

Technical Data of Analysis

S.No.	Analyzed parameters	(Unit of Measurement)	Observed Value	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	pH@25°C	-	7.43	6.5-8.5	6.5-8.5	IS 3025 (Part 11):2022 (Electrometric method)
2	Turbidity	NTU	0.91	1	5	IS 3025 (Pt 10):2023
3	Total Dissolve Solid @180°C	mg/L	506	500	2000	IS 3025 (Pt 16):2023
4	Fluoride	mg/L	0.37	1	1.5	APHA 24 th Edition 4500-F Method C (Electrode method) 2023
5	Total Hardness	mg/L	304	200	600	IS 3025 (Part 21):2019
6	Total Alkalinity	mg/L	412	200	600	IS 3025 (Part 23):2023
7	Chloride	mg/L	35.7	250	1000	IS 3025 (Part 32):2019
8	Iron	mg/L	0.03	1	1	APHA 24 th Edition 3500-Fe Method B (Phenanthroline Method) 2023
9	Sulphate	mg/L	41.6	200	400	APHA 24 th Edition 4500-SO4 Method E (Turbidity Method) 2023
10	Calcium	mg/L	36.87	75	200	IS 3025 (Part 40):2023
11	Magnesium	mg/L	51.5	30	100	IS 3025 (Part 46):2019
12	Nitrate	mg/L	34.2	45	45	APHA 24 th Edition 4500-NO3 Method D (UV Screening Method) 2023
13	Colour (Hazen)	-	1	5	15	IS 3025 (Part 4): 2021
14	Odour	-	Agreeable	-	-	IS 3025 (Part 05):2022
15	Taste	-	Agreeable	-	-	IS 3025 (Part 08):2023

Note

1. This Certificate refers only to the sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 10 days (in case of non-perishable items only) from the date of issue of tests reports.
5. Remark- Parameters above permissible limits are written in **Bold**.
6. Sample not Collected by Laboratory.
7. Disclaimer :- Information Provided by Customer (Location, Date of Sample Collection & Name of Sample Collector)
8. Source is not verified by the laboratory.

Reviewed by

Yashwant Singh
(Deputy Technical Manager)

Authorized Signatory

Shailendra Singh Rajawat
(Quality/Technical Manager)
07/07/26
District Level Water Analysis Laboratory
UP/N (Rural) Aligarh
Phone-6350499124

Laboratory Contact details
Email- waterlab.alig@gmail.com